

Water Sample Range Report

Island Health

Facility Name: B.C. PARKS RALPH RIVER CAMPGROUND
Facility Type: 2-14 (DWS)
Date Range: Jan 1 2016 to Dec 31 2016
Date Created: Jan 13 2017

Sampling Site	Date Collected	Total Coliform	E. Coli	Fecal Coliform
<u>Well #2, Well Plate #14042, Well #2, Well Plate #14042, Dist. site, Semi-monthly</u>				
	13-Apr-2016	L1	L1	
	25-Apr-2016	L1	L1	
	03-May-2016	L1	L1	
	30-May-2016	L1	L1	
	08-Jun-2016	L1	L1	
	22-Jun-2016	L1	L1	
	06-Jul-2016	L1	L1	
	26-Jul-2016	L1	L1	
	02-Aug-2016	L1	L1	
	30-Aug-2016	L1	L1	
	12-Sep-2016	L1	L1	
	26-Sep-2016	<u>L1</u>	<u>L1</u>	
	Total Positive:	0	0	0
<u>Well #1, Well Plate #14046, Well #1, Well Plate #14046, Dist. site, Semi-monthly</u>				
	13-Apr-2016	L1	L1	
	25-Apr-2016	L1	L1	
	? 03-May-2016	L1	L1	
	? 22-Jun-2016	L1	L1	
	06-Jul-2016	L1	L1	
	26-Jul-2016	L1	L1	
	02-Aug-2016	L1	L1	
	30-Aug-2016	L1	L1	
	12-Sep-2016	L1	L1	
	26-Sep-2016	<u>L1</u>	<u>L1</u>	
	Total Positive:	0	0	0
<u>Well #3, Well Plate #14043, Well #3, Well Plate #14043, Dist. site, Semi-monthly</u>				
	13-Apr-2016	L1	L1	
	25-Apr-2016	L1	L1	
	03-May-2016	L1	L1	
	30-May-2016	L1	L1	
	08-Jun-2016	L1	L1	
	22-Jun-2016	L1	L1	
	06-Jul-2016	L1	L1	
	26-Jul-2016	L1	L1	

02-Aug-2016	L1	L1	
30-Aug-2016	L1	L1	
12-Sep-2016	L1	L1	
26-Sep-2016	<u>L1</u>	<u>L1</u>	
Total Positive:	0	0	0

Audit Well #1, Well Plate #14046, Audit Well #1, Well Plate #14046, Dist. site, Monthly

Audit Well #2, Well Plate 14042, Audit Well #2, Well Plate 14042, Dist. site, Monthly

Audit Well #3, Well Plate #14043, Audit Well #3, Well Plate #14043, Dist. site, Monthly

Result Values: E - estimated L - less than G - greater than

Interpreting Sample Reports


In VIHA, the results of drinking water sampling are reported using the following coding system:

- L1 Less than 1 (no detectable bacteria) - Meaning: No bacteria present
- OG Overgrown - Meaning: Too many background bacteria to give an accurate count
- EST Estimated Count
- and
- A Sample not tested; Too long in transit
- C Sample leaked/broken in transit
- D Sample not tested; No collection date given
- T Sample submitted unsatisfactory. Exceeded 30 hours holding time, please resample.
- NS No sample received with requisition

Samples that contain total coliform:	0	0.00% of total
Samples that contain e. coli:	0	0.00% of total
Samples that contain fecal coliform:	0	0.00% of total
Number of positive samples in last 30 days:	0/0	
Total number of samples:	34	

Comments:

2016 - Water Quality + Sampling Program in compliance
 - Ensure sampled twice a month each April through Sept.


 Environmental Health Officer
 Jan 26 2017

FEB 22 2017

FOR FURTHER INFORMATION PLEASE CALL: Baratta, Joseph (250) 850-2110 Campbell River Office

Operator

Ministry of Environment B.C. Parks
 A 2080 Labieux Road
 Nanaimo, BC
 V9T 6J9

(250) 751-3100