

**JUNIPER BEACH PARK WATER SYSTEM ANNUAL REPORT OF
MONITORING**

Report of Monitoring under Section 15 of the *Drinking Water Protection Act*

GENERAL INFORMATION

Date of report: Nov. 1, 2012

Period of monitoring covered by this report: May 1, 2012 to September 30, 2012 (Park operating Season)

Water supply system operating permit number: 0660877

Location of water supply system: Juniper Beach Provincial Park – 15 km west of Savona on Hwy #1

Name of owner(s)¹: Province of British Columbia, Ministry of Environment, Parks and Protected Areas

Name and contact information for person to contact if anyone has questions regarding this report.

Bruce Petch, Area Supervisor, 1259 Dalhousie Drive, Kamloops BC V2C 5Z5

Phone: (250) 371-6216

MONITORING RESULTS

(For each of the tables in this section, any incidents of values exceeding levels established by the Drinking Water Protection Regulation or the terms and conditions of the Operating Permit must be highlighted.)

Monitoring for coliform / E-coli as per section 11 of the Act and section 8 of the Regulation

Date	Results
2012 Operating Season	<i>May 2012-Bacterial water sample positive for 13 total coliforms present at the outside tap. May 2012-Bacterial water sample positive for 1 total coliform present at the pumphouse.</i>
	<i>After two consecutive negative samples, the Boil Water Notice was rescinded on June 29.</i>

Results of Monitoring for any Other Parameters Required by the Operating Permit

Specify relevant provisions of operating permit and parameters sampled for:

No other sampling parameters required by the operating permit.

Date	Results
n/a	n/a

Results of any additional monitoring required by the Drinking Water Officer during the year

Specify additional monitoring requirements imposed:

No additional monitoring requirements imposed.

Date	Results
n/a	n/a

IMPROVEMENT ACTIONS AND PLANS

1. Indicate the steps taken to address circumstances in which monitored parameters exceeded permitted levels and to avoid similar occurrences in the future.

A Boil Water Notice was in place for the month of June until two consecutive negative samples were taken.

2. Indicate improvements or remedial actions that are required by the operating permit or Drinking Water Officer, and the required timelines for such improvements or remedial actions.

3. Indicate any additional plans for improvements, including timelines.

Chlorination system was installed June 2012