

FLOOD RESPONSE PLAN PROCEDURES

Local Authority Utility Operations Procedures

EXAMPLE

General Procedures for Flood Control

In the event that severe flooding should occur, the following measures will be taken:

1. In the event of severe flooding, close all air release valves,
2. Mark valves in event of breaking watermains, which may cause contamination,
3. Keep a close check on 88th Avenue Bridge, Fraser River Bridge, Fort Langley and 96th Avenue Salmon River Bridge to prevent a loss of water in case of bridge failure,
4. Check with City of _____ to get water at 196th Street and 96th Avenue in event of emergency,
5. Will have valve and hydrants checked and marked on map in flooding area,
6. Check 201st Street north of 96th Avenue P.R.V. station,
7. Check buried watermain crossing at Glover Road and Salmon River Bridge.

BC Gas Procedure

(Insert applicable procedures here.)

BC Hydro Procedure

(Insert applicable procedures here.)

Dam Safety Procedures
(If applicable)

(Insert applicable procedures here.)

Dike Safety Procedures
(If applicable)

(Insert applicable procedures here.)