



Schedule "A"
Minimum Flow Requirements
Ramona Creek Power Project
Conditional Water Licence: C131286
Water File: 2002919 Land File: 2409421

Minimum flow measured immediately below the respective point of diversion, or as specified in the OPPR will be:

Month	Minimum Instantaneous Flow, cubic metres per second [m3/s]
	Ramona Creek PD80736
January to December	0.12

Month	Minimum Instantaneous Flow, cubic metres per second [m3/s]
	Marten – s-p'il-us Creek PD80735
January to December	0.042

Remko Rosenboom
Water Manager

Dated at Surrey, British Columbia, this 14th day of November, 2016