



Province of British Columbia

Water Act

CONDITIONAL WATER LICENCE

The owner(s) of the land to which this licence is appurtenant are hereby authorized to divert and use water as follows:

- a) The stream on which the rights are granted is Belcharton Creek.
- b) The point of diversion is located as shown on the attached plan.
- c) The date from which this licence shall have precedence is June 13, 2012.
- d) The purpose for which this licence is issued is irrigation.
- e) The maximum quantity of water which may be diverted for irrigation purpose is 160 cubic metres per day at a rate not to exceed 0.00833 cubic metres per second.
- f) The period of the year during which the water may be used is April 1 to September 30.
- g) The land upon which the water is to be used and to which this licence is appurtenant is North East Quarter, Section 14, Township 18, Except: Firstly: Explanatory Plan 8712, Secondly: Reference Plan 13699, Thirdly: Part Subdivided By Plan 21118, and Fourthly: Part Subdivided By Plan 24629, New Westminster District of which 8.1 hectares may be irrigated.
- h) The authorized works are screened intake, flow measuring device, pump, pipes, and irrigation sprinklers, which shall be located approximately as shown on the attached plan.
- i) The construction of the said works has been completed and the water is being used. The licensee shall continue to make regular beneficial use of the water in a manner authorized herein.
- j) The diversion of water authorized under this licence may be restricted or prohibited at any time by an Order in writing of an Engineer under the Water Act, in order to maintain a minimum flow in the stream for the preservation of fish and other aquatic life.
- k) The licensee shall install a flow measuring device to the satisfaction of an Engineer under the Water Act.

- l) The licensee shall retain flow meter records for five years, for inspection upon request by an Engineer under the Water Act.
- m) The intake must be screened to prevent the entry of aquatic wildlife. For further guidance, refer to the Fisheries and Oceans Canada Freshwater Intake End-of-Pipe Fish Screen Guideline at <http://www.dfo-mpo.gc.ca/Library/223669.pdf>.



Remko Rosenboom, M.Sc., A.Ag.
Regional Water Manager