



Schedule "A"

Minimum Flow Requirements

Chickwat Creek Power Project

Conditional Water Licence: C133254


Water File: 2004386 Land File: 2409412

Minimum flow measured immediately below the point of diversion, or as specified in the OPPR will be:

Month	Minimum Instantaneous Flow, cubic metres per second [m3/s]	
	Chickwat Creek	Chickwat Creek
	PD80728	"multi-route obstacle" downstream of anadromous fish barrier
	(1)	(2)
January 1 st	0.32	0.6
January 7 th	0.32	0.6
January 8 th	0.32	0.0
February	0.32	0.0
March	0.32	1.9
April	0.61	1.9
May 1 st	0.61	1.9
May 7 th	0.61	1.9
May 8 th	0.61	0.2
June	0.61	0.2
July	0.61	0.2
August	0.32	0.2
September	0.32	0.2
October 1 st	0.32	0.2
October 23 rd	0.32	0.2
October 24 th	0.44	0.6
November	0.44	0.6
December	0.32	0.6

Notes:

1. Column (2) flows are in addition to Column (1) flows, i.e. $0.32 + 0.6 = 0.93$ m3/s, if required by the Chickwat Creek Fish Adaptive Management Plan
2. Column (2) flows are implemented on January 1st in accordance with the analysis in the Chickwat Creek Fish Adaptive Management Plan, or as approved by the Water Manager.


Remko Rosenboom, M.Sc., A.Ag.
Water Manager

Dated at Surrey, British Columbia, this 21st day of June, 2016